

Eneria
Direction Service & Maintenance
GE et Onduleurs – Moteurs Industriels
Rue de Longpont - BP 10202
91311 Monthéry Cedex
Tél. +33 (0)1 69 80 21 00
Fax +33 (0)1 69 80 21 50

Kuwait Petroleum

Petroleumkaai 7
2020 Antwerp

BELGIUM

Monthéry, May 23th, 2013

Item : **Q8 MAHLER CP5 - GAS ENGINE OIL TEST ON G3500B (FRANCE)**

Dear Sir, dear Madam,

We testify that the test follow up and the engine inspection were carried out according to CATERPILLAR requirements.

We confirm all the points and details mentioned in the report, which indicates that the inspected parts were found in good serviceable condition, correspond to the observations we made during the test and at the occasion of the engine inspection.

Therefore, we consider that the test results are satisfactory and we approve your lubricant **Q8 MALHER CP5** for Caterpillar engines of type **G3500B** in **cogeneration application with natural gas**.

Bests Regards



Laurent NIVERTS
Service Manager
S&M GEU